

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0026:317 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Simplex, 100 Simplex Drive, Westminter, MA 01441
Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Models 4906-9127, 4906-9129 wall mount and Models 4906-9128 and 4906-9130 ceiling mount multi-candela horn/strobes. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Electrical: 16-33 Vdc
Candela: 15, 30, 75, 110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number, electrical/candela rating, and UL label.

APPROVAL: Listed as multi-candela horn/strobes with a signaling appliance suitable for the hearing impaired when used with listee's separately listed fire alarm control units. All models require the use of Model 4905-9938 (CSFM Listing No. 7125-0026:235) sync control module unless the horn/strobes are used with the listee's Model 4010 (CSFM Listing No. 7170-0026:226) or 4100 (CSFM Listing Nos. 7170-0026:250 and 7165-0026:251). Refer to listee's Installation Instruction Manual for details.

07-22-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**